

Delivery of the unit to the Forks Substation
 441 West E Street
 Forks, Washington.

_____ (Weeks)

Location of Plant of Manufacturing: _____

Recommended Spare Parts List to be attached.

Maximum Guaranteed Losses: Complete following page.

The following information must be supplied at the time of the bid:

Excitation Current – 69 kV Delta Connection			
	Currents		
	H ₁	H ₂	H ₃
100% Voltage	_____ amps	_____ amps	_____ amps
105% Voltage	_____ amps	_____ amps	_____ amps
110% Voltage	_____ amps	_____ amps	_____ amps
Sound Levels – 69 kV Delta Connection			
Calculated Sound Level:	_____ db @ 12 MVA		_____ @ 20 MVA
Guaranteed Sound Level:	_____ db @ 12 MVA		_____ @ 20 MVA
Price Adder for Sound Test:			\$
Price for Short Circuit Test in accordance with Section III, Item 24:			\$

Loss Testing – At Order Time		
Phase Angle Errors:	Potential Transformers	
	Current Transformers	
	Wattmeters	
Power Factor at which wattmeter calibrated:		
Wattmeter Input Voltage as percent of maximum wattmeter input voltage during testing of this unit:		
Wattmeter Input Current as percent of maximum wattmeter input current during testing of this unit:		
Wattmeter Reading as percent of maximum wattmeter reading during testing of this unit:		
High-Voltage Bushing Information:		

High-Voltage Bushing Manufacturer:	
High-Voltage Bushing Model Number:	
High-Voltage Bushing Creepage Distance:	
Low-Voltage Bushing Information:	
Low-Voltage Bushing Manufacturer:	
Low-Voltage Bushing Model Number:	
Low-Voltage Bushing Creepage Distance:	
Neutral Bushing Information:	
Neutral Bushing Manufacturer:	
Neutral Bushing Model Number:	
Neutral Bushing Creepage Distance:	

Alternate Bid Provisions and Specifications: (Complete descriptive literature must accompany all alternate bids.)

6. Affidavit:

The undersigned hereby certify to their best knowledge and belief that:

- (a) The bid to Public Utility District No. 1 of Clallam County dated _____ has not been prepared by _____ (Seller) and _____ (Manufacturer) in collusion with any other seller of Power Transformers; and
- (b) the prices, terms, or conditions of said bid have not been communicated by the undersigned or by any employee or agent of _____ (Seller) and _____ (Manufacturer) to any other seller of Power Transformers and will not be communicated to any such seller prior to the official opening of said bid.

 Signature of person responsible
 for the preparation of the bid

Signature of person responsible
for the preparation of the bid (Manufacturer)

Signature of person supervising
the above person, where feasible (Seller)

Signature of person supervising
the above person, where feasible (Manufacturer)

Date: _____

7. Contractor Information:

Employer's Identification Number (the number used by companies when filing their Employer's Quarterly Federal Tax Return, U.S. Treasury Department Form 941):	
---	--

8. Bid Security: Attached hereto is a Certified Check, Cashier's Check, or Bid Bond in the amount of _____ Dollars (\$ _____) drawn in favor of Public Utility District No. 1 of Clallam County, this amount being not less than five percent (5%) of the total bid.

Bidder: _____

By: _____

Title: _____

Mailing Address:	
Street Address:	
Telephone Number:	
FAX Number:	
E-Mail Address:	
Manufacturer:	

Date: _____