

ADDENDUM NO. 1
REQUEST FOR QUOTATION DOCUMENTS
FOR
TRENCHING-SR 101 NEAR ELWHA BRIDGE

Quotation Due Date: June 12, 2019
RFQ Number 191003

Addendum No. 1 addresses issues and questions raised at the Pre-Bid Meetings held on June 5th and 6th, 2019.

Question 1:

Since the Olympic Hot Springs Road is "County Right of Way", can the steel plates be left over night over the trench without 24/7 flagging?

Answer 1:

Yes. This is County Right of Way and the County has said that it will be ok to use steel plates to cover the trench over night without 24/7 flagging, as long as the steel plates are tacked with cold mix and the appropriate flagging signs are in place.

Question 2:

Will WSDOT allow "water filled barriers" in place of the "concrete barriers" stated in the Request for Quotation?

Answer 2:

The "water filled barriers" will not be approved for this project.

This addendum consists of one (1) page(s). This addendum must be acknowledged and included with any bid submitted.

PUBLIC UTILITY DISTRICT
NO. 1 OF CLALLAM COUNTY

Acknowledged by:

By: 
John Purvis, Assistant General Manager

By: _____ (Bidder)

Date: 6/10/19

Date: _____