

**EXHIBIT "B"**

**TABLE 1**

**MINIMUM GROUNDLINE CIRCUMFERENCE**

Minimum effective pole circumferences after deductions for hollow heart, enclosed pockets, or exposed pockets have been made. See Tables 2, 3, and 4 for defect deductions.

<b>CEDAR POLES</b>	
<b>Pole Length (Feet)</b>	<b>Minimum Groundline Circumference (Inches)</b>
30	27.0
35	29.5
40	31.0
45	32.5
50	34.5
55	35.5
60	37.0
65	38.0
70	39.0
75	40.0
80	41.5