



**REQUEST FOR BID
BID NUMBER 210804**

ADDENDUM NO. 1

Date: February 22, 2022

Re: TRANSMISSION POLE FROM CHERRY STREET TO RACE STREET

This Addendum No. 1 forms a part of the Contract Documents and modifies the original bidding documents dated January 31, 2022. This Addendum is issued to clarify, revise, add to, or delete from the original bidding documents. Bidders shall determine the work affected by the Addendum items.

This Addendum consists of:

Answering the following questions the District has received:

1. **Will the poles be pre-drilled?** No.
2. **Who supplies backfill?** The contractor supplies the backfill.
3. **What is the backfill material?** 3/4" minus crushed rock. See section 6.1 of "Specifications for installation".
4. **In accordance with Article VI of the Contract "Payment of Prevailing Wages" it states laborers, workers or mechanics employed on the project are to be paid prevailing wages. Does this include sub contracted truck drivers for shipping/trucking of materials from Clallam County PUD yard to job site location?** Yes, all workers on the job are to be paid prevailing wage.
5. **How will the new 556AAC come delivered?** It will be on wood reels of approximately 7000ft in length each. Contractor must pick up the reels from the PUD Central Warehouse Facility on Hooker road, in Carlsborg WA.

This addendum consists of one (1) page. **THIS ADDENDUM MUST BE ACKNOWLEDGED AND INCLUDED WITH ANY BID SUBMITTED.**

Addendum No. 1 acknowledged by:

Firm: _____

By: _____

(Signature)

(Typed or Printed)

Title: _____ Date: _____