



**REQUEST FOR BID
BID NUMBER 220805**

ADDENDUM NO. 2

Date: April 25, 2022
Re: FORKS SUBSTATION CONSTRUCTION
To: ALL PROSPECTIVE BIDDERS

This Addendum No. 2 forms a part of the Contract Documents and modifies the original bidding documents dated April 12, 2022. This Addendum is issued to clarify, revise, add to, or delete from the original bidding documents. Bidders shall determine the work affected by the Addendum items.

This Addendum consists of:

BID DUE DATE EXTENDED

Bid due date is extended to, Tuesday, May 3, 2022, 2:30 p.m. Pacific Time

Sealed bids will be received by Clallam County PUD No. 1 until 2:30 p.m. Pacific Time, on Tuesday, May 3, 2022. At 3:00 p.m. Pacific Time, a public bid opening will take place in the Boardroom at the District's Main office located at 104 Hooker Road, Sequim WA 98382. Contractors who submit a bid must be prequalified in accordance with Washington State Regulations (RCW 54.04.085) prior to receiving bid proposals.

CHANGES TO EXHIBIT C- SPECIFICATIONS DRAWINGS AND MATERIAL

- a. Revision E4-2-3 *Repositioned diagrams to fit everything into the drawing.*

CLARIFICATIONS AND ANSWERS TO QUESTIONS

- a. **C1 on the bid sheet states (1) ea but the foundation plan (C1-1) states (2) new foundations**
C1 is the foundation for the Aframe. Yes it should be 2 foundations even though it's just for one item.
- b. **C2 on the bid sheet states (2) ea but the foundation plan (C1-1) states (1) new foundation. It also refers to FDN detail drawing E4-2-3 however that drawing is for C8 the control house.**
C2 is just one foundation.
- c. **C4 on the bid sheet states (1) ea, the foundation plan (E4-1) shows (1) foundation but on (C1-1) it states (3) foundations**
C4 is just one foundation with 3 risers on it for the arrestor supports.
- d. **C10 on the bid sheet states (6) ea but the foundation plans (C1-1) states (5) new foundations. It also refers to FDN detail drawing E4-2-3 however that drawing is for C8 the control house.**
C10 is 6 foundations.

- e. On sheet (C1-1) it shows a temp fence, would you like us to provide that? Would that item go under B1 Site prep?

Temp fence provided by contractor. This could go on site prep.

- f. E4-2-3 the profile view is cutoff.

Repositioned diagrams so everything fits into the view pane.

This addendum consists of three (3) pages. **THIS ADDENDUM SHEET MUST BE ACKNOWLEDGED AND INCLUDED WITH ANY BID SUBMITTED.**

Addendum No. 2 acknowledged by:

Firm: _____

By: _____
(Signature)

(Typed or Printed)

Title: _____

Date: _____