220806 NEAH BAY SUBSTATION TRANSFORMER
3PH 12MVA POWER TRANSFORMER WITHOUT LOAD TAP CHANGER
BID OPENING: AUGUST 31, 2022, 3:00 P.M.
ENGINEER'S ESTIMATE $320,000

BIDDER	PROPOSAL COMPLETE	BID BOND	ALL ADDENDUMS	BID PRICE no sales tax	ALTERNATIVE BID YES/NO or NOTES	NO LOAD LOSSES	LOAD LOSSES	DELIVERY TIME IN WEEKS
WEG TRANSFORMERS USA	Y	Y	Y	$ 601,196.00	NO	8.4	51	85-90
VIRGINIA GEORGIA TRANSFORMER	Y	Y	N- missing #4	$ 456,748.00	NO	7.1	58.1	40-45
NIAGARA POWER TRANSFORMER CORP	Y	N	Y	$ 557,305.00	NO	7.8	57.1	104