220807 FORKS SUBSTATION TRANSFORMER
3PH 10/12/14 MVA POWER TRANSFORMER WITHOUT LOAD TAP CHANGER
BID OPENING: SEPTEMBER 1, 2022, 3:00 P.M.
ENGINEER'S ESTIMATE: $320,000

BIDDER	PROPOSAL SEALED / COMPLETE	BID BOND	ALL ADDENDUMS	BID PRICE no sales tax	ALTERNATIVE BID YES/NO or NOTES	NO LOAD LOSSES	LOAD LOSSES	DELIVERY TIME IN WEEKS
NIAGARA POWER TRANSFORMER CORP	Y	Y	Y	$ 552,056.00	N	7.2	46.7	104
VIRGINIA GEORGIA TRANSFORMER	Y	Y	Y	$ 533,850.00	N	7.1	43	40-45
WEG TRANSFORMERS USA	Y	Y	Y	$ 570,750.00	N	7.19	45.8	85-90