

**240804 OLD BEAVER CAMP SUBSTATION TRANSFORMER
3PH 12/16/20 MVA POWER TRANSFORMER WITHOUT LOAD TAP CHANGER
BID OPENING: JUNE 11, 2024, 3:00 P.M.
Engineer Estimate: \$517,000**

BIDDER	BID BOND	BID PRICE no sales tax	ALTERNATIVE BID YES/NO or NOTES	ADDENDA ACKNOWLEDGED	PREVIOUS TESTED MED XFMR	DRAWING OF COIL BRACING INCLUDED	NO LOAD LOSSES	LOAD LOSSES	DELIVERY TIME IN WEEKS
WEG	Y	\$ 895,484.00	NO	N/A	N	N	8.78	43.1	70
WHITEFISH ENERGY	Y	\$ 688,364.07	NO	N/A	Y	Y	-	-	59
VIRGINIA TRANSFORMER	Y	\$ 951,909.00	NO	N/A	N	N	7.7	41.4	60-65

IMPORTANT NOTE: THIS DOCUMENT DOES NOT REPRESENT SELECTION OF AN APPARENT LOW BIDDER OR PROJECT AWARD. THE DETERMINATION WILL BE MADE ONLY AFTER A MORE THOROUGH REVIEW OF ALL BIDS IS COMPLETED.