

**240805 DEER PARK SUBSTATION TRANSFORMER  
3PH 20/26/33 MVA POWER TRANSFORMER WITH LOAD TAP CHANGER  
BID OPENING: JUNE 13, 2024, 3:00 P.M.  
Engineer Estimate: \$1,360,000**

BIDDER	BID BOND	BID PRICE no sales tax	ALTERNATIVE BID YES/NO or NOTES	RECEIPT OF ADDENDA(S)	LOCATION OF PLANT OF MANF	RECOMMENDED SPARE PARTS LIST	DRAWING OF COIL BRACING INCLUDED	LIST OF PREVIOUS TESTED MED XFMR	NO LOAD LOSSES	LOAD LOSSES	DELIVERY TIME IN WEEKS
VIRGINIA TRANSFORMER	Y	\$ 2,016,500.00	N	Y	POCATELLA, ID	Y	N	N	14.0	74.0	75-80
WEG TRANSFORMERS USA	Y	\$ 1,878,304.00	N	N	WASHINGTON, MO	Y	N	Y	14.4	65.0	70
WHITEFISH ENERGY HOLDINGS LLC	Y	\$ 1,725,935.90	N	Y	CORNELIO PROCOPIO, PARANA, BRAZIL	Y	Y	Y	18.6	87.3	59

**IMPORTANT NOTE:** THIS DOCUMENT DOES NOT REPRESENT SELECTION OF AN APPARENT LOW BIDDER OR PROJECT AWARD. THE DETERMINATION WILL BE MADE ONLY AFTER A MORE THOROUGH REVIEW OF ALL BIDS IS COMPLETED.