



**REQUEST FOR BID
BID NUMBER 240807**

ADDENDUM NO. 1

Date: August 15, 2024

Re: TWO (2) TRANSFORMERS - OLD BEAVER CAMP AND DEER PARK

To: ALL PROSPECTIVE BIDDERS

This Addendum No. 1 forms a part of the Contract Documents and modifies the original bidding documents dated August 9, 2024. This Addendum is issued to clarify, revise, add to, or delete from the original bidding documents. Bidders shall determine the work affected by the Addendum items.

This Addendum consists of:

Answers to questions and clarifications

1.) Will set to pad upon delivery is part of the supplier scope?

The District will offload the transformer from the truck. Please schedule with the District two (2) weeks prior to arrival. As stated in instructions, delivered Monday through Thursday, except District recognized holidays, between 7:00 a.m. and 3:00 p.m.

2.) Will the PUD accept transformers / the components made in China?

For concerns and challenges posed to coordinate and conduct in-person Factory Acceptance Test (FAT), the District will not accept transformers manufactured in China. Bidders may submit auxiliary components that are made in China as long as it meets all local, state, and federal guidelines, requirements, rules, and laws pertaining to electric utilities. Bid proposals with auxiliary components that are made in China will not be accepted if the applicable rules and regulations are not met. The lowest responsible bidder may be provided with the opportunity to replace non-conforming China made components with conforming components without changing the bid price before seeking the District's governing board approval for contract award.

This addendum consists of one (1) page. **THIS ADDENDUM SHEET MUST BE ACKNOWLEDGED IN BID SUBMITTAL IN SECTION II - PROPOSAL.**