

Clallam Bay Sekiu Water Infrastructure Upgrades, Phase 3  
September 25, 2024

Contractor Questions and Answers:

- Question: Generic bid bond form or do you have a specific form you want used?  
Answer: Bid Bond:
  - If you choose to provide a bid bond in place of other options, the Bid Bond shall be issued by the Surety in accordance with Section B1 Instruction to Bidders, Part 4. For your information, the Surety's formwork has been acceptable on past projects.
  
- Question: You need to have a qualified fusion technician- why the 3 required projects of installing 6 Inch hdpe of 1000 feet of longer?  
Answer: HDPE Fusion Experience:
  - The requirements of Supplemental Bidder Responsibility Criteria will be enforced, and this includes Part B in the Instructions to Bidder. In other words, the listed HDPE experience will be required.
  
- Question: Bid Item #A13- Crushed surfacing Top Course or Base Course- is it required to meet WSDOT material requirements?  
Answer Crushed Surfacing:
  - Crushed Surfacing Top and Base Course is required to meet WSDOT material requirements as specified.
  
- Question: What is the Engineer's Estimate?  
Answer: Engineer's Estimate
  - Engineer's estimate is \$1,897,000